



**AR CLEAN
ENVIRO LABS**

Water, Food & Environment Testing Laboratory

Recognized by MOEF & CC | Certified by ISO 9001:2015

8-85/1/F5, 1st floor, Plot No. 10 & 25
Sainagar, Peerzadiguda, Medipally,
Medchal Malkajgiri (Dist.),
Hyderabad-500098, Telangana, India
Ph : +91 8121165649 | 8801676472
E-mail : cleanenvirolabs@gmail.com
www.arcleanenvirolabs.com



TC- 14660

TEST REPORT

Name and Address of the Client:

M/s. Sri Sloka School
Gandi Maisamma.

ULR No : TC1466026000004023F
Sample Registration : 02409/07/26-001
Test Report No : CEL/W/02409/07/26-001
Report Issued Date : 08.07.2026
Work Order Reference : Nil
Date of Receipt : 03.07.2026

Group : Water ✓
Discipline : Chemical & Biological
Sample Description : RO Drinking water
Sample Quantity : 2 Liters x500ml
Sample Packing : Plastic Bottle & Sterile Container

Date of Registration : 03.07.2026
Date of Commencement of Testing : 03.07.2026
Date of Completion of Testing : 08.07.2026
Sample Condition of Receipt : Found Ok

Sampling Details

Date of Sampling : 03.07.2026

Environment Condition: Temperature :27.5° C, Humidity : 69.7%

Sampling Method: APHA 24th Edition-1060-B(2023)
ARCEL/MB/SOP-01 (Microbiology)

Sample Location: From Site.

Sample Collected By: CEL Representative (Ashok)

TEST RESULT

S. No	TEST PARAMETERS	TEST METHOD	UNITS	RESULTS	Acceptable Limits (As Per IS: 10500:2012)
1.	pH@25.0°C	APHA 24th Edition 4500 H+ B(2023)	--	7.22	6.5 - 8.5
2.	Electrical Conductivity	APHA 24th Edition 2510-B(2023)	µs/cm	117	Not Specified
3.	Total Dissolved Solids	APHA 24th Edition 2540-C(2023)	mg/l	52	Max. 500
4.	Turbidity	APHA 24th Edition 2130-B(2023)	NTU	< 1.0	Max.1.0
5.	Color	APHA 24th Edition 2120-C(2023)	CU	< 5.0	Max.5.0
6.	Total Alkalinity as CaCO ₃	APHA 24th Edition 2320-B(2023)	mg/l	20	Max. 200
7.	Total Hardness as CaCO ₃	APHA 24th Edition 2340-C(2023)	mg/l	24	Max. 200
8.	Calcium as Ca	APHA 24th Edition 3500 Ca-B(2023)	mg/l	< 10	Max. 75
9.	Magnesium as Mg	APHA 24th Edition 3500 Mg-B(2023)	mg/l	< 5.0	Max. 30
10.	Chlorides as Cl	APHA 24th Edition 4500 Cl-B(2023)	mg/l	12	Max. 250
11.	Sodium as Na	IS 3025 (Part 45):2024	mg/l	8.0	Not Specified
12.	Potassium as K	IS 3025 (Part 45):2024	mg/l	1.0	Not Specified
13.	Sulphates as SO ₄	APHA 24th Edition 4500 SO4-2 E(2023)	mg/l	< 5.0	Max. 200
14.	Iron as Fe	APHA 24th Edition 3500 Fe B(2023)	mg/l	< 0.5	Max. 1.0
15.	Fluoride as F	APHA 24th Edition 4500 F- D(2023)	mg/l	0.20	Max. 1.0
16.	Silica as SiO ₂	APHA 24th Edition 4500 SiO2 C(2023)	mg/l	< 0.1	Not Specified
17.	Phosphorous	APHA 24th Edition 4500 P-C (2023)	mg/l	< 1.0	Not Specified
18.	Nitrates as NO ₃	APHA 24 th Edition - 4500 NO ₃ -C(2023)	mg/l	< 1.0	Max. 45
BIOLOGICAL PARAMETERS					
19.	Total Plate Count	IS 1622: 1981	Cfu/ml	11	Not Specified
20.	Coliforms	IS 15185:2016	Per 100ml	Absent	Absent/100ml
21.	Escherichia coli	IS 15185-2016	Per 100ml	Absent	Absent/100ml

IS - Indian Standard, APHA - American Public Health Association, CFU - Colony Forming Units.

Remarks: The given water sample is suitable for drinking purpose as per the specifications given by IS 10500:2012


Verified By

T Jyothirmai
(Sr.Chemist)

Authorized By

P. Sahadevudu
(Sr. Microbiologist)

*****END OF THE REPORT*****



F/7.8/03

Issue No & Date: 03&01.09.2024

Amend No. & Date: 00 & 00

AR CLEAN ENVIRO LABS LLP

ISO 14001:2015

ISO 45001:2018

MSME

CYBERABAD MUNICIPAL CORPORATION
DUNDIGAL CIRCLE-59

Lr. No. 02/SWM/CMC/2026

Date: 11.08.2026

//NOC CUM SANITARY CERTIFICATE//

This is to certify that the “SRI SLOKA SCHOOL”, Premises No. H.No.3-211, Ganesh nagar colony, Gandimaisamma , Gandimaisamma Mandal, Dundigal Circle-59, Medchal Dist, Hyd-500043. This office has No Objection to run school and Junior College at building premises and the accommodation provided for each of the several classes is sufficient for the maximum number of pupils taught therein and is properly ventilated and lighted and that the buildings are maintained in substantial repairs. The toilet arrangements are adequate and satisfactory and supply protected drinking water and that in all other necessary aspects, the sanitation is satisfactory.

Note: The NOC is valid only for Sanitation purpose. This certificate is valid for one year from the date of issue.


Asst. Executive Engineer (SWM)
Dundigal Circle - 59, CMC.

To,
The Correspondent,
“SRI SLOKA SCHOOL”,
H.No.3-211, Ganesh nagar colony, Gandimaisamma,
Gandimaisamma Mandal, Dundigal Circle-59,
Medchal Dist, HYD-500043.